	Ref. Certif. No.
	HU-005006-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Surge Protective Device
Name and address of the applicant	Mday(Zhejiang) New Energy Co., Ltd. NO. 299, 10 Latitude Road, Economic Development Zone, Yueqing 325699 Zhejiang, P.R. China
Name and address of the manufacturer	Mday(Zhejiang) New Energy Co., Ltd. NO. 299, 10 Latitude Road, Economic Development Zone, Yueqing 325699 Zhejiang, P.R. China
Name and address of the factory Note: *When more than one factory, please report on page 2*	Mday(Zhejiang) New Energy Co., Ltd. NO. 299, 10 Latitude Road, Economic Development Zone, Yueqing 325699 Zhejiang, P.R. China
Ratings and principal characteristics	Uc:275V AC(1P,2P,3P,4P L/N-PE) 275V AC(1+NPE,3+NPE L-N); 255V AC(1+NPE,3+NPE N-PE) In:20kA; Imax:1)3)40kA, 2)4)50kA; Iimp:2)4)7kA; Up:1.5kV Test Class: 1)3)Class II, 2)4)Class I + Class II Isccr:25kA; Indoor; One port
Trademark / Brand (if any)	mday
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	1)MDN40-275, MYN40-275; 2)MDH7-275, MYH7-275 3)MDN40-275/S, MYN40-275/S; 4)MDH7-275/S, MYH7-275/S (including 1+NPE,3+NPE,1P,2P,3P,4P)
Additional information (if necessary may also be reported on page 2)	This Certificate is Amendment No.1 to CBTC ref. No.HU-005006,dated 2024-06-27,and is issued due to additional remote signaling indicator, for above model 3) and 4)
A sample of the product was tested and found to be in conformity with	IEC 61643-11:2011 See Test Report for National Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	CN24XWY3 002

This CB Test Certificate is issued by the National Certification Body

TÜVRheinland®

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2025-04-30

Signature: Wencai Zhang

10/061SMD 2024-12 rke-simplified

Disclaimer: This is an electronically released document. The authenticity can be verified on the IECEE Website "http://certificates.iecee.org" (1.3s / 0)