C E R T I F I C A T E

of Conformity
Electrical Equipment (Safety) Regulations 2016
(UK SI 2016 No. 1101)

Registration Nr.: AQ 50669735 0001
Report Nr.: CN2467X2 002

Holder:
Mday(Zhejiang) New Energy Co., Ltd.
NO. 299, 10 Latitude Road, Economic Development Zone, Yueqing
325699 Zhejiang
P.R. China

Product: Surge Protector *(Surge Protective Device)*

Test standard: BS EN 61643-11:2012+A11

Identification:
1)MDN40-275, MYN40-275
2)MDH7-275, MYH7-275
3)MDN40-275/S, MYN40-275/S
4)MDH7-275/S, MYH7-275/S
(including 1+NPE,3+NPE,1P,2P,3P,4P)
Technical Data
Uc:275V AC(1P,2P,3P,4P L/N-PE)
Uc:275V AC(1+NPE,3+NPE L-N)
Uc:255V AC(1+NPE,3+NPE N-PE)
In:20kA; Imax:1)3)40kA, 2)4)50kA; Up:1.5kV
Isccr:25kA; Iimp:2)4)7kA; IP20;
Type of SPD:1)3)Type 2, 2)4)Type 1 + Type 2

This certificate of conformity is based on an evaluation of a sample of the above mentioned product, technical report and documentation. This certificate does not imply the assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Certification Body

Date: 2025-05-14

Yongming Yang

TUV Rheinland UK Ltd. TÜVRheinland Conformity Assessment Body

UK CA **The UKCA mark may be used, if all relevant UK Legislations and the UK Declaration of Conformity has been completed.** UK CA

® TÜV, TUEV and TUV are registered trademarks . Utilisatio n and application requires prior approval.

TUV Rheinland UK Ltd.
Friars Gate (Third Floor), 1011 Stratford Road, Shirley, Solihull, B90 4BN